



Fuels Safety Division	Ref. No.: FS-127-08	Rev. No.:
Liquid Fuels Handling Code Adoption Document - Amendment	Date: June 16, 2008	Date:

***IN THE MATTER OF:
THE TECHNICAL STANDARDS AND SAFETY ACT, 2000,
S.O. 2000, c. 16 (the "Act")***

- and -

**ONTARIO REGULATION 223/01 (Codes and Standards Adopted by Reference)
made under the Act**

- and -

**ONTARIO REGULATION 217/01 (Liquid Fuels)
made under the Act**

Subject: Distance for Gasoline to Diesel Dispenser
Sent to: Posted on Web-Site and Distributed to Liquid Fuels Council and RRG

The Director of Ontario Regulation 217/01 (Liquid Fuels) pursuant to section 7 of Ontario Regulation 223/01 (Codes and Standards Adopted by Reference) hereby provides notice of the following:

The Liquid Fuels Handling Code Adoption Document published by the Technical Standards and Safety Authority, dated June 1, 2001, and amended on June 1, 2007 is further amended as follows:

1. Clause 6.3.5 is added:
6.3.5 - Section 6.3.3 does not apply to the dispensing of diesel fuel where a diesel fuel dispenser is more than 6 metres from a gasoline dispenser or where the gasoline dispensers are shut off.
2. This amendment is effective June 30, 2008.

Dated at Toronto this 16th day of June, 2008.

ORIGINAL SIGNED

John Marshall
Director, Ontario Regulation 217/01 (Liquid Fuels)
made under the *Technical Standards and Safety Act, 2000*

Background:

Clause 6.3.5 is added, as it was an allowance included in the previous Liquid Fuels Handling Code and was simply omitted in the current code.