



Fuels Safety Program	Ref. No.: FS-141-09 R2	Rev. No.: 2
ADVISORY	Date: Feb 9, 2009	Date: April 16, 2013

Subject: Secondary Containment Liners
Sent to: Posted on Web-Site and Distributed to LF Council, LF RRG, Fuel Oil RRG, CPPI, CIPMA, OFM, MCS, COHA, ULC, CSAO, OPCA, MPHCA

ULC withdrew listings to the *ORD-C58.9, Secondary Containment Liners for Underground and Aboveground Flammable and Combustible Liquids* on February 28, 2009. The ORD was withdrawn sometime after that.

ULC has since published a new standard, *CAN/ULC-S668-12, Standard for Secondary Containment of Aboveground Flammable and Combustible Liquid Tanks*. However, they will not be providing certification services for this standard.

In view of the above, **TSSA will require applicants to:**

- a) **Provide a letter from a P. Eng. stating that the liner meets the requirements of CAN/ULC-S668-12, Standard for Secondary Containment of Aboveground Flammable and Combustible Liquid Tanks.**
- b) **Provide the manufacturer's specifications for the material and installation instructions.**
- c) **Apply for a variance for the use of unapproved equipment.**